GROUP A
NEW STANDARDS PROPOSED IN
2024 CODE CHANGE CYCLE
LISTED BY STANDARDS ORGANIZATION
STAFF ANALYSES

March 18, 2024
ADDENDUM 1, MARCH 29, 2024

The following are comments by ICC staff regarding certain aspects of standards proposed to be referenced in the ICC Codes by code change proposals submitted for the 2024 Group A Proposed Changes. The comments relate to portions of the criteria for standards contained in Section 4.6 of CP#28 (*see last page of this document*).

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
AAMA STANDARDS			
FS115-24	***IBC-FS:*** *1404.4.1*	***FMA/AAMA/WDMA 500—16*** *Standard Practice for the Installation of Mounting Flange Windows into Walls Utilizing Foam Plastic Insulating Sheathing (FPIS) with a Separate Water-Resistive Barrier*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
AASHTO STANDARDS			
F72-24	***IFC:*** *D103.4*	***AASHTO - GDHS 7th Edition*** *A Policy on Geometric Design of Highways and Streets*	Portions do not appear to be written in enforceable language. See Sections 2.9.1.1, 2.9.1.3, 3.2.4.4. This is more of a design guide. Does not indicate promulgation by a consensus process. Does not appear to require proprietary materials or agencies.
ABTG STANDARDS			
FS115-24 **FS109-24** **FS114-24**	***IBC-FS:*** *1404.4.1*	***ANSI/ABTG FS200.1—2022***	

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
APSP STANDARDS			
SP29-24	***ISPSC:*** *604.2.2*	***ANSI/APSP/ICC-11—2019*** *American National Standard for Water Quality in Public Pools and Spas*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
ASABE STANDARDS			
P162-24, Part I **P162-24, Part II**	***IPC*****:** *G101.2* ***IRC-P*****:** *CI101.2*	***ASABE S626-SEP2016 (R2020)*** *Landscape Irrigation System Uniformity and Application Rate Testing*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
ASHRAE STANDARDS			
RM2-24 **M62-24**	***IRC:*** *M1401.1* ***IMC:*** *1101.1.1*	***ASHRAE 15.2—2022*** *Safety Standard for Refrigeration Systems in Residential Applications*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
M35-24 **M23-24** **M24-24**	***IMC:*** *401.2, 401.2.1, 407, 407.1 408.1.1* ***IBC:*** *1202.1*	***ANSI/ASHRAE/ASHE Standard 170—2021*** *Ventilation of Health Care Facilities*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
P101-24, Part I	***IPC:*** *708.1.11.2*	***A112.36.2/B79.2—2022*** *Cleanouts*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
ASSE STANDARDS			
P127-24 **P128-24** **P129-24** **P130-24** **P135-24** **P136-24** **P141-24** **P134-24**	***IPC:*** *907.1, 907.2, 907.3, 908.2, 918.1, 918.3.1, 918.3.2, 918.9*	***ASSE 1030—2016*** *Performance Requirements for Positive Pressure Reduction Devices for Sanitary Drainage Systems*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
P83-24 **P87-24**	***IPC:*** *608.17.1.1*	***ASSE 1032—23*** *Dual Check Valve Type Backflow Preventers for Carbonated Beverage Dispensers, Post Mix Type, and Non-Carbonated Beverage Dispensers*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
			a consensus draft of ASTM D7445-24.
FS112-24	***IBC:*** *1403.15*	***ASTM D8484—23*** *Standard Specification for Plastic Lumber Materials and Wood-Plastic Composite Materials Used as Exterior Wall Coverings*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. Does not appear to require proprietary materials or agencies.
WUIC49-24 **E92-24**	***IWUIC:*** *504.10*	***ASTM E814—23a*** *Standard Test Method for Fire Tests of Penetration Firestop Systems*	Currently referenced in the IBC, IRC, and the IMC.

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
P116-24			
P117-24, Part I			
P117-24, Part II			
P111-24			
P113-24			

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
S4-24	***IBC:*** *1705.17*	***ASTM WK70807*** *Practice for On-Site Inspection of Installed Board and Wrap Type Fireproofing Materials, Special Inspections*	The Standard was submitted in consensus draft form. Appears to be written in enforceable language. Identification of a consensus process is provided on the co(s)10.7 q201.12C

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
F84-24	***IFC:*** *608.18.4; 2311.5*	***UL 1963—2011*** *Refrigerant Recovery/Recycling Equipment – revisions through March 2021*	Appears to be written in enforceable language. Identification of a consensus process is provided on the cover. ~~Identification of a consensus process is not provided.~~ Does not appear to require proprietary materials or agencies.
F115-24	***IFC:*** *904.2.2, 904.14* ***IBC****: 904.2.2, 904.14*	***UL 2162—2014*** *Commercial Wood-Fired Baking Ovens – Refractory Type – with Revisions through August 2019*	Currently referenced in the IMC.
P149-24	***IPC:*** *1003.4.2*	***UL 2215—19*** *Outline of Investigation for Oil/Water Separators*	Appears to be written in enforceable

CODE CHANGE NUMBER	CODE SECTION(S)	STANDARD	STAFF COMMENTS
		Outline of Investigation for Service, Communication, Information, Education and Entertainment Robots	Does not appear to require proprietary materials or agencies.
M15-24	***IMC:*** *202 New, 917.3*	***UL 3320—2023*** *Outline of Investigation for Robotic Commercial Kitchen Equipment -*	

be specifically referenced in the Code text.

4.6.1.2 The need for the standard to be referenced shall be established.

4.6.2 Standard Content:

4.6.2.1 A standard or portions of a standard intended to be enforced shall be written in mandatory language.

4.6.2.2 The standard shall be appropriate for the subject covered.

4.6.2.3 All terms shall be defined when they deviate from an ordinarily accepted meaning or a dictionary definition.

4.6.2.4 The scope or application of a standard shall be clearly described.

4.6.2.5 The standard shall not have the effect of requiring proprietary materials.

4.6.2.6 The standard shall not prescribe a proprietary agency for quality control or testing.

4.6.2.7 The test standard shall describe, in detail, preparation of the test sample, sample selection or both.

4.6.2.8 The test standard shall prescribe the reporting format for the test results. The format shall identify the key performance criteria for the element(s) tested.

4.6.2.9 The measure of performance for which the test is conducted shall be clearly defined in either the test standard or in Code text.

4.6.2.10 The standard shall not state that its provisions shall govern whenever the referenced standard is in conflict with the requirements of the referencing Code.

4.6.2.11 The preface to the standard shall announce that the standard is promulgated according to a consensus procedure.

4.6.3 New and Updated Standards with Text Revisions:

4.6.3.1 Code change proposals with corresponding changes to the Code text which include a reference to a proposed new standard or a proposed update of an existing referenced shall comply with this section.

4.6.3.1.2 Update of Existing Standards.